Radiation Protection Studies for the Passive Absorber Design

S. Roesler, M. Brugger and D.Forkel-Wirth

Collimation Working Group 12 July 2007


Radiation Protection Aspects

"Direct" 1) Induced radioactivity in components – dose to personnel


- 2) Air activation dose to population and personnel
- 3) Cooling water activation dose to population and personnel


"Indirect" 4) Damage to equipment – dose to personnel


FLUKA calculations





- same geometry as for energy deposition studies
- passive absorber with and without iron shielding
- 180 days of operation at nominal intensity
- annual loss (M.Lamont): 1.15 x 10¹⁶ protons per beam
- horizontal losses














Residual dose rates

One day of cooling









Residual dose rates


One day of cooling


TCAPA with shielding




12 July 2007








Stefan Roesler



Residual dose rates – TCP / TCSG / TCAPA / TCAPC

One week of cooling



Aisle (x = 65-85cm), 180days, 1.15x10¹⁶protons/beam


Stefan Roesler

Area classification

								Page 9
	TABLES	Table 1 —	Synopsis of the	classification of N	on-designated	and Radiation Ar	eas at CERN	
	Area	Dose limit	Ambient dose equivalent rate		Specific airborne	Specific surface	Access,	Monitoring,
	classification	Dose Innit	At permant workplaces	In low-occupancy areas	radioactivity	contamination	Personnel categories	Personal dosimetry
	Non-designated Area	1 mSv / y	< 0.5 µSv h ⁻¹	< 2.5 µSv h⁻¹	0.05 CA	-	no restriction, all	passive or active, not required
	Supervised Radiation Area	6 mSv / y	< 3 µSv h ⁻¹	< 15 µSv h ⁻¹	< 0.1 CA		supervised, radiation workers and VCT	passive or active, personal dosimete
n Area	Simple Controlled Radiation Area		< 10 µSv h ⁻¹	< 50 µSv h ⁻¹	< 0.1 CA			active, personal dosimete
l Radiation Area	Limited Stay Area	20 mSv / y		< 2 mSv h ⁻¹	<100 CA	< 4000 CS	controlled, radiation workers	active,
Controlled	High Radiation Area			<100 mSv h ⁻¹	< 1000 CA	< 40000 CS	workers	personal dosimete and operational dosimeter

12

ALARA - 1



CRITÈRES

2.

2.1

CRITÈRE DE DÉBIT	DE DOSE	
Débit d'équivalent de c	ose prévisionnel (\dot{H}) dans la zon	e d'intervention :
50 µS	v∙h⁻¹ 2 mS	v∙h⁻¹
50 µs niveau I	v·h ⁻¹ 2 mS niveau II	sv·h ⁻¹ niveau III

2.2 CRITÈRE DE DOSE INDIVIDUELLE

Équivalent de dose prévisionnel individuel (H_i) pour l'intervention, ou pour l'ensemble des interventions de même nature lorsque celles-ci sont répétées plusieurs fois sur une année :

TTT TTT	100	ISv	1 mSv
niveau I niveau II niveau II	niveau I	niveau II	niveau III

2.3 CRITÈRE DE DOSE COLLECTIVE

Équivalent de dose prévisionnel collective (H_c) pour l'intervention, ou pour l'ensemble des interventions de même nature lorsque celles-ci sont répétées plusieurs fois sur une année :

500	μSv 10	mSv
niveau I	niveau II	niveau III


Tableau 1 — Synthèse des exigences.


ALA	RA		2
-----	----	--	---


Type d'intervention		-	répétitives / génériques		ponctuels / unitaires		
Niveau de risque		Ι	II	III	Ι	II	III
Dosimétrie individuelle		•	•	•	•	•	•
Dosimétrie opérationnelle sans alarme		•			•		
Dosimétrie opérationnelle avec alarme			•	•		•	•
	Docts. descriptifs		0	0			0
Dossier de sécurité	Docts. justificatifs		0	•			•
	Docts. d'exploitation		0	0			ο
Analyse de risques radiologiques		•	•	•	•	•	•
Calculs radiologiques / codes simples				•			•
Calculs radiologiques / codes élaborés				•			•
Justification par analyses multi-critères			0	•		0	•
Prise en compte du retour d'expérience		•	•	•	•	•	•
Dossier d'intervention en milieu radioactif	DIMR de niveau I	•			•		
	DIMR de niveau II		•			•	
	DIMR de niveau III			•			•
Cartographie dosimétrique		0	•	•	0	•	•
Relevé de décisions du comité ALARA				•			0
Fiche d'écart / Retour d'expérience		0	0	0	0	0	0

requiredrecommended

Stefan Roesler







Summary - 1

"Direct" 1) Induced radioactivity in components – dose to personnel

- dose rates at PA about one half of that at first secondary collimator
- iron slabs increase dose rates at PA by 20-30% and decrease dose rates at magnets by about 20%
- short cooling times (up to one week): several 10 mSv/h on contact about 1 mSv/h in aisle
- long cooling times (>1 month): several mSv/h on contact several 100 μSv/h in aisle
- received doses have not yet been calculated (scenarios needed)
- classification as high radiation area
- work planning and optimization according to ALARA Level 2 or 3

2) Air activation – dose to population and personnel

- small impact on air activation expected (within 10%)
- isotope production has still to be calculated

Summary - 2

"Direct" 3) Cooling water activation – dose to population

- additional contribution not yet studied but no significant change of total activity expected
- cautions for PA handling similar to collimators and magnets

"Indirect" 4) Damage to equipment – dose to personnel

- increased lifetime of warm magnets (positive!)
- increased damage to cables in vicinity, not yet studied but expected to be similar or lower than at collimators

Summary - 3

Uncertainties:

- annual loss (1.15 x 10¹⁶ protons per beam)
- Phase 2 collimators not considered (but losses at nominal intensity used)
- distribution of losses among different collimators, here only horizontal losses considered (conservative?), will change with Phase 2 collimators
- FLUKA geometry (factor 2?), models and methods (< 30%)
- statistical uncertainties (~10%)

Open questions (?):

- water flow control
- water handling during exchange
- alignment
- scenarios for work on PA's (*e.g.,* replacement) and on any components in their vicinity
- structural damage and containment of the tungsten (brittle under radiation?)